

PRESSURE VESSEL ENGINEERING  
120 RANDALL DRIVE  
WATERLOO ON N2V 1C6

**Date:** February 21, 2017

**Account #:** 45363

**Journal #:** 67357

**Our File #:** 5611806

**Attn:** CATHERINE DIPLOCK

**Re:** Application for Design Registration

The design, as detailed in your, PVE-9379, for a Pressure Vessel is accepted for registration as follows:

**Registered To:** WORTHINGTON (STAKO)      **CRN:** R3244.51

**MDMT:** -20 deg F

**MAWT:** 149 deg F

**MAWP:** 312 psig

**Drawing #:** 1536.01.000

**Drawing Revision:** A

**Conditions Of Registration:**

Registration of a 600mm dia. LPG tank F60005740 type 40 ASME.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

boiler.designregistration@safetyauthority.ca  
Design Administration

**cc:**