



PRESSURE VESSEL ENGINEERING
120 RANDALL DRIVE
WATERLOO ON N2V 1C6

Date: February 21, 2017

Account #: 45363

Journal #: 67356

Our File #: 5611805

Attn: CATHERINE DIPLOCK

Re: Application for Design Registration

The design, as detailed in your, PVE-9379, for a Pressure Vessel is accepted for registration as follows:

Registered To: WORTHINGTON (STAKO) **CRN:** R3243.51

MDMT: -20 deg F

MAWT: 149 deg F

MAWP: 312 psig

Drawing #: 1537.01.000

Drawing Revision: A

Conditions Of Registration:

Registration of a 650mm dia. LPG tank F65007340 type 40 ASME.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

boiler.designregistration@safetyauthority.ca
Design Administration

cc: