

PRESSURE VESSEL ENGINEERING  
120 RANDALL DRIVE  
WATERLOO ON N2V 1C6

**Date:** March 20, 2017  
**Account #:** 45363  
**Journal #:** 67594  
**Our File #:** 5613267

**Attn:** CATHERINE DIPLOCK

**Re:** Application for Design Registration

The design, as detailed in your, PVE-9124, for a Pressure Vessel is accepted for registration as follows:

**Registered To:** WORTHINGTON (STAKO)      **CRN:** R3069.51

**MDMT:** -20 deg F

**MAWT:** 149 deg F

**MAWP:** 312 psig

**Drawing #:** 1540.01.000

**Drawing Revision:** A

**Conditions Of Registration:**

Registration of a F680 type-40 LPG Tank.

This design was registered based on a technical review performed by the province of initial registration in accordance with the Association of Chief Inspectors policy on reciprocal recognition of design review.

**Reviewer's Notes:**

Inside Mount: 312 psig @149 Deg F with no corrosion allowance.

Outside Mount: 250 psig @ 149 Deg F with 0.031" corrosion allowance.

Contact me if you have any questions. The invoice for registration will be forwarded under separate cover.

SHARON PETERS

boiler.designregistration@safetyauthority.ca  
Design Administration

**cc:**